



Australian Capital Territory
Gazette

SPECIAL GAZETTE

No. S100, Monday 7 June 1993

BUILDING ACT 1972

EXEMPTION

No. 51 of 1993

Lr 31/5/04

I revoke Determination No 166¹ of 1992 made under Section 27(1) of the Building Act 1972 as published in the Australian Capital Territory Gazette No S231 on 24 November 1992. Under Section 27(1) of the Building Act 1972, I EXEMPT the ACT PUBLIC WORKS AND SERVICES GROUP, being a government agency, from the application of the provisions of the Building Code specified in the Schedule hereunder in respect of the building works known as Tuggeranong Indoor Swimming Centre.

SCHEDULE

Clause D1.13	Table D1.13
Clause F2.3	Table F2.3 Class 9b Buildings
Clause ACT G1.1(d) (i)	
Clause E2.1	Table E2.1
Clause ACT E1.7	
Clause ACT D2.103	


Terence Connolly
Minister for Urban Services

6 May 1993

AUSTRALIAN CAPITAL TERRITORY

BUILDING ACT 1972

EXEMPTION

No. 51 of 1993

This Instrument revokes Determination No 166 of 1992 made under Section 27(1) of the Building Act 1972 as published in the Australian Capital Territory Gazette No S231 on 24 November 1992 and exempts ACT Public Works and Services, being a government agency, from the application of the provision of the Building Code specified in the Schedule in respect of the building works known as Tuggeranong Indoor Swimming Centre.

It is a requirement of the Building Act 1972 that all work undertaken on the project shall be in accordance with the Building Code of Australia (BCA).

To determine which exemptions would be appropriate while still achieving the required level of amenity, fire safety and design efficiency the Design Manager (Daryl Jackson Alastair Swayn Pty Ltd) has tested the requirements of the BCA against provisions at other pools within Australia, requirements of the Health Department of NSW and various international standards. The Design Manager after assessing the problem has recommended five (5) exemptions to the requirements of the BCA.

The proposed exemptions have been examined by ACT Public Works and Services and circulated for comment and endorsement to the ACT Fire Brigade, ACT Office of Sport and Recreation and the ACT Building Controller. All of these organisations have supported the exemptions to the BCA.

This process has resulted in a recommendation that five (5) exemptions be made to the requirements of the Building Code of Australia, as listed in the Schedule of Exemptions set out in the Instrument.

A summary of these modifications and the specific Clauses of the Building Code of Australia which are affected is as follows:

Item 1

To permit a reduction in the number of toilet facilities in the complex;

Exemption from the requirements of the following;
Clause D1.13, Table D1.13 and Clause F2.3, Table F2.3 Class 9b Buildings.

Item 2

To permit a relaxing of the maximum gradients applying to the floors of the pool;

Exemption from the requirements of the following;
Clause ACT G1.1(d) (i).

Item 3

To permit the deletion of a mechanical smoke ventilation system;

Exemption from the requirements of the following;
Clause E2.1, Table E2.1.

Item 4

To permit the deletion of thermal and smoke detectors over the water areas;

Exemption from the requirements of the following;
Clause ACT E1.7.

Item 5

To permit the deletion of the requirement for testing of slip resistance of paving in public areas;

Exemption from the requirements of the following;
Clause ACT D2.103.