

Australian Capital Territory

Gas Safety (Codes of Practice) Approval 2009

Disallowable instrument DI2009—187

made under the

***Gas Safety Act 2000*, s 65 (Codes of Practice)**

1 Name of instrument

This instrument is the *Gas Safety (Codes of Practice) Approval 2009*.

2 Commencement

This instrument commences on the day after it is notified.

3 Approval of code of practice for connecting gas to uninspected consumer piping system

I approve the code of practice at schedule 1.

Andrew Barr
Minister for Planning

05 August 2009

Australian Capital Territory

Gas Safety Act 2000

Code of practice for connecting gas to uninspected consumer piping systems

1. This code is an approved code under the *Gas Safety Act 2000*, s 65 (Codes of Practice).
 2. A person must not connect gas to a consumer piping system unless an inspector has inspected and passed the system.
 3. Section 2 does not apply to—
 - (1) connecting gas only for the purpose of the responsible gas fitter or an inspector inspecting or testing a consumer piping system while the gas fitter or inspector attends the system for the testing or inspecting; and
 - (2) a part of a consumer piping system comprising an extension (the ***extension***) to an existing consumer piping system (the ***system***) if the system can be lawfully connected to the gas supply.
-