

AUSTRALIAN CAPITAL TERRITORY

CANBERRA SEWERAGE AND WATER SUPPLY REGULATIONS
(AMENDMENT)

EXPLANATORY STATEMENT

No. 27 of 1984

The Canberra Sewerage and Water Supply Regulations (Amendment) deletes from sub-regulation 80 (27) of the Canberra Sewerage and Water Supply Regulations the requirement that a flushing cistern give a minimum effective flush of 9 litres. The amendment validates the use of dual flushing cisterns into the Canberra Sewerage System.