

DETERMINATION: Ozone Protection Act 1991

Under Sub-section 24(1) of the *Ozone Protection Act 1991*, I, the Pollution Control Authority, hereby determine that the course specified below is an approved course for the purposes of the Act.

- Institute:** ACT Institute of Technical and Further Education - School of Electrical and Electronic Studies
- Course:** TAFE Metal and Engineering National Curriculum Module NRO3 - Refrigerants.
- Syllabus:** Practices in the servicing and installation of commercial and domestic refrigeration and air conditioning to minimise the release of ozone depleting substances into the atmosphere. This involves the following sections:
- . Differentiation between the various refrigerants in common use.
 - . Safe handling of refrigerants.
 - . Correct procedures for reclaiming refrigerants and evacuating systems.
 - . Correct procedures for leak detecting refrigeration systems.
 - . Identification of the causes of contamination in refrigeration system and procedures for dealing with them.
 - . An understanding of the A.C.T. *Ozone Protection Act 1991* and regulations.
 - . An understanding of ozone depletion and its causes and consequences.

Duration: 20 hours.

Persons wishing to undertake this course must be undertaking a TAFE award courses in refrigeration and air-conditioning.



A H Crawley
Pollution Control Authority

27 May 1992